

## **ADDENDUM NO. 1**

### **REPLACE PRESSBOX AND SKYBOX HVAC AT MALONE STADIUM UNIVERSITY OF LOUISIANA AT MONROE**

**MAY 10, 2013**

THE FOLLOWING MODIFICATIONS AND/OR CLARIFICATIONS SHALL BE MADE TO THE DRAWING AND PROJECT MANUAL FOR THE CAPTIONED PROJECT:

#### **DRAWINGS**

1. **Sheet M-1:**
  - a. Change duct size 96/16 to 18x20. Plenum below 60/18 R/A up shall be 18" wide x 20" deep x 96" long.
2. **Sheet M-2:**
  - a. Connect ¾" cold water line to existing ¾" line above ceiling of Mechanical Room 217. Provide ¾" ball valve at connection. Rise into Penthouse and install sillcock on east wall of Penthouse. Exact location shall be as directed by Engineer. Sillcock shall be Zurn Z-1345 or Woodford B-74-C, non-freeze type. Piping shall be Type L copper.

#### **EQUIPMENT APPROVALS**

1. Cooling Towers:
  - a. American Cooling Tower, ACF Series
2. A Type Supply Diffuser:
  - a. KRUEGER, 5145OA Series
3. B&C Type Return Grille:
  - a. KRUEGER, EGCS Series
4. D&E Type Supply Grilles:
  - a. KRUEGER, DPL Series
5. Fire Dampers:
  - A POTTORFF, VFD-10-A Series